

Certificate of Conformity (COC)



Certificate Holder : Shenzhen Aohai Digital Power Co., Ltd.
2501, Building 1, Huide Building, North Station Community, Minzhi Street, Longhua, Shenzhen, Guangdong, China

Date of Original Issue : 2024-04-07

Date of Last Revision : --

Date of Expiry : 2027-04-06

Certificate Number : PCS-24-1033

Product : Bidirectional Converter

Ratings : See appendix on page 2

Brand/Trademark : **AOHAI**
奥海科技

Model(s) : AH-3KSL-G2, AH-3.6KSL-G2, AH-4KSL-G2, AH-4.6KSL-G2, AH-5KSL-G2, AH-6KSL-G2

Test Laboratory : SGS-CSTC Standards Technical Services Co., Ltd. Guangzhou Branch

Testing Report : SUEE240300002351

Test Standard : C10/11: 2021



This is to certify that the product has been tested and was found to comply with the requirements of the standard(s).
The above-mentioned product is certified according to the requirements of ISO/IEC 17065:2012.

Christopher Hee
Certification Officer


SGS Testing & Control Services Singapore Pte Ltd
30 Boon Lay Way #03-01 Singapore 609957



PD-2016-15



SGSSGsts




The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.

APPENDIX

Certificate Number: PCS-24-1033

Model	AH-3KSL-G2	AH-3.6KSL-G2	AH-4KSL-G2	AH-4.6KSL-G2	AH-5KSL-G2	AH-6KSL-G2
PV String Input Data						
Start-up voltage	120 V					
Rated input voltage	360 V					
Max. input voltage	550 V					
MPPT operating voltage range	90 V~550 V					
Max. input current	2*16 A					
Max. short current	2*20 A					
Recommended Max. PV power	6 kW	7.2 kW	8 kW	9.2 kW	10 kW	10.8 kW
Battery Input Data						
Battery type	Li-Ion					
Battery voltage range	42 V~59 V					
Min. full load voltage	45 V	45 V	46 V	46 V	50 V	50 V
Max. charging/discharging current	66.7 A	80 A	87 A	100 A	100 A	120 A
Continuous charging/discharging power	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW
AC Input / Output (On-grid)						
Nominal grid voltage	L/N/PE, 230 Vac					
Nominal grid frequency	50 Hz					
Max. AC current	16 A	16 A	22 A	22 A	27 A	27 A
Rated AC power	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW
Max. AC power	3 kVA	3.6 kVA	4 kVA	4.6 kVA	5 kVA	6 kVA
Output power factor	1 default (adjustable+/-0.8)					
AC Output (Back-up)						
Nominal grid voltage	L/N/PE, 230 Vac					
Nominal grid frequency	50 Hz					
Max. AC current	16 A	16 A	22 A	22 A	27 A	27 A
Rated AC power	3 kW	3.6 kW	4 kW	4.6 kW	5 kW	6 kW
Max. AC power	3.6 kVA	4.32 kVA	4.8 kVA	5.52 kVA	6 kVA	6 kVA
Operating temperature range	-25 °C ~+60 °C, with derating above 45° C					
Protection degree	IP65					
Protective class	Class I					
Cooling method	Natural Cooling					



The use of this Certificate is subjected to the General Conditions for Certification Services accessible at <https://www.sgs.com/en/terms-and-conditions> and Certification Agreement for SGS Product Certification Scheme (PCS). Any unauthorised alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. This Certificate is part of a full report and should be read in conjunction with it. This Certificate cannot be reproduced except in full, without prior approval of the Company. This Certificate remains the property of SGS Testing & Control Services Singapore Pte Ltd and shall be returned upon request.